

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. MEMO/2025

Dated: 5/06/2025

It is certified that an inspection team headed by S. P. PANDEY MEDICAL OFFICER ,
(Name of Officers with designation) from PHC, SALON, RAEBARELI, U.P. (Name of Department/
Office) inspected the **RAJEEV GANDHI CONVENT SCHOOL,**
LAHUREPUR, SALON, RAEBARELI, U.P. (Name & Address of the school) on 4/06/2025 (date of
inspection) and found that the **RAJEEV GANDHI CONVENT SCHOOL** (Name of school) has safe
drinking water facilities for the students and members of staff of the institution and is maintaining
the hygienic sanitation condition in the school building & the campus as per norms prescribed by
the Central/ State/ U.T. Govt

The above is valid for a period of ONE YEAR

Signature with Seal: ...

Name: S. P. PANDEY
Designation: MEDICAL OFFICER
Name & Address of the Office / Department : PHC, SALON

MEDICAL OFFICER 05/06/2025
PHC, SALON, RAEBARELI

To

MANAGER
RAJEEV GANDHI CONVENT SCHOOL
LAHUREPUR, SALON, RAEBARELI, U.P.
(Name & Address of the Institution)

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. MEMO/2025

Dated: 10/08/2025

It is certified that an inspection team headed by Mr. ANIL KUMAR (chemist)

(Name of Officers with designation) from DIVISION OFFICE ,U.P. JAL NIGAM RAEBARELI PHED

inspected the RAJEEV GANDHI CONVENT SCHOOL, LAHUREPUR, SALON , RAEBARELI,U.P.

(Name & Address of the school) on 09/08/2025(date of inspection) and on the basis of Water Test

Report (Attached) bearing no C/RAEBARELI/AUGUST25/02

of Office of the Executive Engineer U.P. JAL NIGAM RAEBARELI (PHED Lab) certified that the

RAJEEV GANDHI CONVENT SCHOOL, LAHUREPUR, SALON , RAEBARELI,U.P (Name of


school) has safe drinking water facilities for the students and members of staff of the institution.

School is also maintains the hygienic sanitation condition in the school building & the campus as

per norms prescribed by the Central/ State/ U.T. Govt.

This certificate is valid till ONE YEAR

Signature with Seal:


जनपदीय प्रयोगशाखा
उ० प्र० जल निगम
रायबरेली

10/08/2025

To

Manager

RAJEEV GANDHI CONVENT SCHOOL
LAHUREPUR, SALON RAEBARELI,U.P.

(Name & Address of the
Institution)

Name

: ANIL KUMAR

Designation

: CHEMIST

Name & Address of the Office / Department : U.P. JAL NIGAM

RAEBARELI

Water Analysis Report



District Level Water Analysis Laboratory
Office of the Executive Engineer , U.P. Jal Nigam Raebareli,

Report No.: C/Ayo/Aug 2025/01 Date: 09/08/2025 No. of Pages: 1

Office Name and Address Date: 08/08/2025

Ref. Letter No. & Date 0

Basic Details of Sample

District	Raebareli.	Block	Salon
Gram Panchayat	Raebareli.	Village	Lahurepur
Habitation	Raebareli.	Location	Raebareli
Water Source	Tubewell/ Nalkoop	Sample Code	C/RAEBARELI/AUGUST 25/02
Quantity of Sample	1000 mL (Normal)	Sampling date	08/08/2025
Sample Received Date	08/08/2025	S. collected by	Mo. Shahrukh
Sampling Method Used	NA	Sample Depositor	Mo. Shahrukh
Analysis Start Date	08/08/2025	Analysis Completion date	09/08/2025

S. No.	Analysed Parameters	Observed Value	Specification as per IS 10500:2012 (Second Revision)		Ref. Methods of Analysis
			Acceptable Limit	Permissible Limit	
1	2	3	4	5	6
1	Odour	Agreeable	Agreeable	Agreeable	IS 3025 (Part 5): 2018
2	Taste	Agreeable	Agreeable	Agreeable	IS 3025 (Part 8): 2023
3	pH	7.22	6.5-8.5	6.5-8.5	IS 3025 (Part 11): 2022, Electrometric Method
4	Colour (Hazen units)	1	5	15	APHA 24rd Edition -2120-Colour Method B (Platinum Cobalt Visual Comparison): 2023
5	Turbidity (NTU)	0.0	1	5	IS 3025 (Part 10):2023 (Nephelometric method)
6	Total Dissolved Solids, mg/l	132	500	2000	IS 3025 (Part 16): 2023 (Gravimetric method)
7	Chloride (as Cl), mg/l	18	250	1000	IS 3025 (Part 32): 2019 Argentometric method
8	Total Alkalinity, (as CaCO3) mg/l	120	200	600	IS 3025 (Part 23): 2023 (Potentiometric and indicator method)
9	Total Hardness, (as CaCO3) mg/l	108	200	600	IS 3025 (Part 21): 2019 (EDTA method)
10	Calcium (as Ca), mg/l	12	75	200	IS 3025 (Part 40): 2019 EDTA Titrimetric method
11	Magnesium (as Mg), mg/l	08	30	100	IS 3025 (Part 46): 2023 (Volumetric method)
12	Sulphate (as SO4), mg/l	0.34	200	400	APHA 24rd Edition -4500-SO4 Method E (Turbidimetric Method): 2023
13	Nitrate (as NO3), mg/l	0.20	45	No relaxation	APHA 24rd Edition -4500- NO3 Method B (UV Screening Method): 2023
14	Fluoride (as F), mg/l	0.06	1.0	1.5	APHA 24rd Edition -4500-F Method C (Ion-Selective Electrode Method): 2023
15	Iron (as Fe), mg/l	0.04	1.0	No relaxation	APHA 24rd Edition -3500-Fe Method B (Phenanthroline Method): 2023
16	Total Arsenic (as As), mg/l	0	0.01	No relaxation	APHA 24rd Edition -3500 Method B (Silver Diethyldithiocarbamate Method): 2023
17	Total Coliform (MPN/100mL)	0	0.0	0.0	IS 1622 :2019

All These parameters are under NABL Scope, BDL-Below Detection Limit, NA- Not Analysed

- Note:**
- This certificate refers only to the particular sample(s) submitted for analysis.
 - This certificate shall not be reproduced, except in full, unless written permission for the publication of an approved abstract has been obtained from Head of Laboratory.
 - The analysis results reported in this certificate are valid at the time of and under the stated conditions of measurements.
 - Sample(s) will be stored up to 07 days (in case of non-perishable items only) from the date of issue of analysis reports, unless otherwise specified.
 - Parameters above Permissible Limit are written in bold.
 - Sample(s) with any parameter value above Accepted Limit will only be used for oral consumption, if no other source is available.
 - Sample is not Collected by Lab.

Satish Kumar
SATISH KUMAR
(Report prepared by)

Anil Kumar
(Report prepared by) 09/08/2025
U.P. JAL NIGAM
RAEBARELI